

## Woodlarks Camp Site Risk assessment

Activity: Electrical Safety.

Risk Assessor: Lynne Cooper

Assessment completed: Jan 2026.

Review date: Jan 2027

What are the hazards?	Who might be harmed and how?	What are you already doing to control the risks?	Initial Risk	What further action do you need to take to control the risks?	Revised Risk
Failure of Electrical equipment	Electrocution Fire Injury to operatives or bystanders	<p>5-year fixed wiring installation checked and certified throughout site.</p> <p>Portable Appliance Testing (PAT) carried out annually on all Woodlarks appliances in use. New appliances not applicable until in use for a year.</p> <p>Any faulty equipment withdrawn from service and reported for repair or disposal.</p> <p>The Camp Leaders Handbook gives advice on electrical safety to be adhered to by site users.</p>	Med	<p>Site contractors to use low voltage portable tools where possible.</p> <p>All extension leads to be completely unwound before use.</p> <p>Leads need to be routed in a manner not to cause trip hazard.</p> <p>Do not operate electrical equipment in wet conditions, unless suitable safety measures taken.</p> <p>All non-Woodlarks equipment brought to site by helpers / campers is requested to be visually checked for signs of failure or damage.</p>	Low