



Woodlarks Campsite CIO

Woodlarks Camp Site Trust

In-Service Inspection and Testing Policy

Version Control Log

Version	Date	Summary of Changes / Notes	Author
1.0	18/11/2025	Convert to new CIO format	MJ

Document Approval

Version	Date	Person Responsible	Approved by	Signature
1.1	April 2026		Trustees	Email

Distribution History

Version	Date	Circulated to
1.1	29/04/2026	Added to Woodlarks Document Library and Website

Review Interval

Version	Date of Next Review	Interval
1.1	29/04/2029	3 years

Table of Contents

1	Introduction	3
	Overview	3
	Definitions	3
	Personnel	3
	Purpose	3
1.1	Scope	3
1.2	Legal Framework	3
2	1.3 Our policy	4
1.4		
3	1.5 New items	5
1.6		
4	1.6 Rejected items	5
5	Equipment brought onto site	5
6	Record Keeping	6
7	Appendix 1 Inventory labels and PAT labels	6
8	Appendix 2: Visual Inspection	7
9	Appendix 3 Data Collection Form.....	7

1 Introduction

Overview

- 1.1.1 There is a legal requirement for employers (in this context the Woodlarks Campsite CIO (“Woodlarks”) is considered an employer) to ensure portable electrical equipment is safe
- 1.1.2 Woodlarks has determined that Portable Appliance Testing will be conducted on a regular basis to minimise the risk of electrical accidents.
- 1.1.3 This document outlines the procedure to ensure that all our electrical appliances are tested regularly, and that the tests are documented.
- 1.1.4 This document covers the testing of portable appliances. The fixed installation and any permanently wired appliances are inspected separately

Definitions

- 1.2.1 For definitions used in this policy, please refer to the separate document on our [website](#).

Personnel

- 1.3.1 For allocated personnel for this policy, please refer to separate document on our [website](#).

Purpose

- 1.4.1 The purpose of this policy is to maintain the electrical safety of portable appliances

Scope

- 1.5.1 This policy applies to both:
 - [Woodlarks Campsite CIO - 1214811](#)
 - [Woodlarks Camp Site Trust - 306148](#)
- 1.5.2 This policy applies to:
 - Trustees
 - The Management Committees
 - The Warden and Secretary
 - Woodlarks Volunteers, including Working Parties and Winter Events
- 1.6
 - Camps, Schools and Winter Events hiring the site
 - Contractors
- 1.5.3 It covers all activities taking place on the campsite, whether residential or day use.

Legal Framework

- 1.6.1 Both of the following publications were consulted in writing this policy:
- The Institution of Engineering and Technology (IET) publication ["Code of Practice for In-Service Inspection and Testing of Electrical Equipment 5th Edition"](#) is the defining document for in-service testing of electrical appliances.
 - Similar information is available in the Health and Safety Executive (HSE) document "Maintaining portable and transportable electrical equipment" (<http://www.hse.gov.uk/pubns/priced/hsg107.pdf>) .
- 1.6.2 This document is not intended to reiterate the detailed contents of these documents. It is intended to state how Woodlarks will carry out PAT testing to conform with these documents.
- 1.6.3 In developing the policy, we have used the IET risk assessment procedure and have considered who will use the equipment, its level of usage, storage, and areas of use. It is possible that children and vulnerable adults will use equipment under supervision. The levels of use of most of the equipment are quite light. Some equipment will be used only during the camping season (late April to September), some equipment will only be used during the closed season, some only at Christmas. No equipment will be subjected to heavy use. All storage areas are dry.
- 1.6.4 The 2019 version was revised r, based on experienced gained since 2010.

2 Our policy

- 2.1.1 Based on the HSE document's "Light Industrial" usage category. All equipment which is deemed eligible for PAT testing will be examined annually. The annual inspection combines a visual inspection and electrical test. The inspection will be conducted before the start of the camping season using a calibrated PAT tester by a "Competent Person".
- 2.1.2 At the same time visual inspection will be made to identify problems such as damaged insulation and incorrect fusing. There are some notes on visual inspection in Appendix 2 on page 7.
- 2.1.3 When required extra visual inspections will be arranged, for example Christmas decorations are inspected after unpacking, as this is a time when damage might be sustained.
- 2.1.4 The Camp Leaders' Handbook advises users of the need to be vigilant when using electrical appliances.
- 2.1.5 All items are labelled twice, one label identifies that the appliance has been electrically tested, the other gives an inventory number for tracking purposes. There's more information on inventory labels in Appendix 1 on page 6.
- 2.1.6 Pass labels are valid for 13 months. This allows some latitude in planning the next annual inspection, considering the difficulty in arranging visits by our volunteers. Additionally, as equipment usage is light in the early part of the year this will not greatly increase risk.
- 2.1.7 An inventory is kept of all items in the form of a spreadsheet. The section on Record

Keeping on page 6 gives example of records.

3 New items

- 3.1.1 It is possible that new items will be put into service during the year, missing the electrical test. We assume that a new item will be electrically safe.
- 3.1.2 A new item is defined as brand new with evidence of purchase. Any item that is donated will not be considered new unless we have proof of purchase.
- 3.1.3 Any such items will be prominently labelled as below.



This should show the current year e.g. 2020 in the 2020 season

- 3.1.4 At the next electrical test these items will receive the normal labelling.

4 Rejected items

- 4.1.1 Any item failing an electrical test or visual inspection will be repaired and retested. Equipment which fails this process or is otherwise no longer required will be disposed of. Disposal will take regard of the [Waste Electrical and Electronic Equipment Directive](#) (WEEE Directive).

5 Equipment brought onto site

- 5.1.1 Woodlarks ensures that all equipment supplied by us will be tested and labelled. However, there are circumstances when other equipment will be brought onto site. These include
 - Equipment hired by the Trust
 - Equipment brought by campers, such as wheelchair chargers
 - Equipment brought by volunteers for use at working parties
 - Equipment used by contractors
- 5.1.2 Equipment hired by Woodlarks will be sourced from a reputable supplier who must ensure certification for each piece of equipment.
- 5.1.3 Woodlarks cannot exercise control over equipment brought by visitors e.g. campers. The Camp Leaders' Handbook asks Camp Leaders to exercise discretion as to what

equipment is used. Much equipment used by disabled campers will be PAT tested by their care provider.

- 5.1.4 Working party volunteers may bring equipment on site for their personal use with permission from the working party leader or the Warden.
- 5.1.5 Contractors working on site must ensure that their equipment is tested.
- 5.1.6 Woodlarks Campsite reserves the right to PAT test any equipment brought onto site.

6 Record Keeping


- 6.1.1 The results of the electrical tests are recorded electronically as in the example below. The items highlighted in red are failed items.

CODE (UID)	Description	Details	Type	Visual	Earth Current (A)	Earth Resist(Ohms)	Insulation Mohms	Leakage mA	Load kVA	Notes	
BCS016	Fridge	(in rest room)	1	P	Pass	0.2	<0.04	>99.99	0.1	0.05	none
BCS021	Bed	(in rest room)	2	P	Pass			>99.99			none
BCS027	Bed	Dormitory	2	P	Pass			>99.99			none
KT1029	Fly Killer		1	P	Pass	0.2	<0.04	>99.99	0.1	0.05	none
KT1030	Kettle	Kerwood	1	P	Fail	0.2	>19.99				Earth Problems
PH8501	Pump		1	P	Fail						Earth Problems & Corrosion
PH8502	Electric Radiator		1	P	Fail						Earth Problems & Corrosion
SS2003	Cd Radio	Goodmans	2	P	Pass			>99.99			none

- 6.1.2 Where an item that appeared in the previous year's inventory cannot be found, the item will be marked as failed and missing. If the item subsequently reappears, it must be retested before being put into use.
- 6.1.3 The "Type" column refers to whether the item is a type 1 item (with earthed case/chassis) or a Type 2 item (double insulated).
- 6.1.4 The records are reviewed to see if the policy needs revision on an annual basis.
- 6.1.5 When a contractor tests or inspects equipment on our behalf, we need to have copies of all these results in our PAT folder.

7 Appendix 1 Inventory labels and PAT labels

- 7.1.1 The inventory label identifies each item uniquely and consists of a two letter and four-digit code. Please note that we use inventory labels on many items, having an inventory label does not necessarily imply that an item must be PAT tested. Items will be tested if they have a connection to mains electricity.



7.1.2 A sample PAT label is shown below.



7.1.3 The fields are straightforward, the “DATE OF TEST” is the date of the electrical test, the “RETEST DATE” is set as thirteen months later. This is the crucial date. If this date has passed the appliance must be set aside until it can be retested.

7.1.4 The “INITIALS” are those of the Competent Person, and the “APPLIANCE NUMBER” reflects the Woodlarks inventory label number.

8 Appendix 2: Visual Inspection

8.1.1 The following topics should be considered in a visual inspection

- Is there any damage to the casing, cable or plug?
- Are there any signs of overheating on the plug or casing?
- Is the cable securely held by the cable grip if fitted?
- Is the proper fuse fitted?
- Is the equipment positioned to avoid strain on cables?
- Are the ventilation points obstructed?
- Is there overloading of extension leads or multi-blocs?
- Are any cables creating trip hazards?
- Are cables located to avoid damage? e.g. not trapped by furniture or doors
- Is the equipment safely located, e.g. could an electric kettle fall into a sink?

9 Appendix 3 Data Collection Form

9.1.1 A sample of a completed data collection form is shown on the next page. Please note

that this form is used as a memory aid and checklist whilst conducting tests. The data used to create electronic records (as outlined in the section “Record Keeping” on page 6) is stored in the PAT testing machine.

Asset #	Description	Type	Pass /fail	Retest date	notes
UC4065	10m extension reel	egxt	P	25/04/20	
BC5170	Vermin deterrent	2	p	25/04/20	
UC4096	Vermin deterrent	2	p	25/04/20	
KT1037	Vermin deterrent	2	p	25/04/20	
UC4095	Vermin deterrent	2	p	25/04/20	
UC4097	Vermin deterrent	2	p	25/04/20	
UC8007	Fly zapper	1	p	25/04/20	
UC8008	R H Stick blender	2	p	25/04/20	
TS3066	Buffalo toaster	1	p	25/04/20	
KT1032	Sainsbury sandwich toaster	1	p	25/04/20	
UC4074	Sainsbury red kettle	1	P	25/04/20	